



COHASSET SEWER COMMISSION
Meeting Minutes

Tuesday July 11, 2023

In Attendance:

*Paul Kierce
Dan Coughlin
William McGowan
Brian Joyce*

*Wayne Sawchuk
Robert Scott
Scott Papa
Peter Lyons*

Meeting Called to Order: 9:34 am

Next meeting: July 25, 2023- 9:30am start

Abatement: 107 Ripley Road

MOTION: Motion made by Wayne Sawchuk to abate \$500 from 107 Ripley Road. Bill Second. The motion was approved by a unanimous roll call vote.

110 Jerusalem Road

Adding an additional grinder pump due to existing pool and new garage; 2 toilets and 3 sinks. The pool filter will not be connected to the sewer line.

MOTION: Motion made by Paul Kierce to approve the sewer connection. Bill second. The motion was approved by a unanimous roll call vote.

Sewer Break – Jerusalem Road

Linden Drive north to Rust Way

The two lowest properties had a break at the pump connection due to the excessively high pressure.

Opened the valve to Hull to relieve the pressure.

Value testing should be done and Brian will develop a plan to fix this issue – flush both ways – and will send to the board once it's completed.

Woodard & Curren I&I

Inspected 10,000 ft of pipe. Groundwater was higher than average. All pipes had signs of infiltration. There was Moderate corrosion in the concrete manholes pipes. A few places were unable to be cleaned due to lack of access or too much pressure going into homes causing issues.

MOTION: Motion made by Bill McGowan to adjourn. Wayne second. The motion was approved by a unanimous roll call vote.

Meeting Adjourned: 10:16am